

Identification # \_\_\_\_\_  
Country \_\_\_\_\_  
Date of Inspection \_\_\_\_\_

### LARGE DAY CARE HOME BUILDING INSPECTION FORM

1. Does the building meet the intent of Volume VII, Residential Code? Yes\_\_\_ No\_\_\_
2. If an addition has been built for this use, does it meet Volume VII? (N/A if no new addition) N/A\_\_\_ Yes\_\_\_ No\_\_\_
3. Are all walls and ceilings in rooms which are used for day care purposes, and those spaces that are part of the exit path, gypsum board construction? Yes\_\_\_ No\_\_\_
4. a. Does each room used for day care purposes have, on that level, access to two remotely located outside doors? Yes\_\_\_ No\_\_\_  
    \*\* IF answer is yes, skip to Question 5. If 4a is no, answer 4b.  
    b. Is an exterior door located in each room used for day care purposes? Yes\_\_\_ No\_\_\_  
    \*\* If answer is yes, skip to Question 6.
5. Are all rooms located so as not to have a dead-end distance in excess of 20 feet? Yes\_\_\_ No\_\_\_
6. Is the exit door located no more than 48" above grade? Yes\_\_\_ No\_\_\_
7. Do all locks on doors require no more than one operation to release the door? Yes\_\_\_ No\_\_\_
8. a. Does the facility have a manual fire alarm device? Yes\_\_\_ No\_\_\_  
    b. Is the device audible throughout the facility? Yes\_\_\_ No\_\_\_  
    c. Is the device easily identifiable as a fire alarm device? Yes\_\_\_ No\_\_\_
9. Are all unoccupied spaces, such as basements, laundry rooms, and fossil fuel fired furnace rooms provided with approved labeled automatic smoke and/or heat detectors? Yes\_\_\_ No\_\_\_
10. Is the total area of all windows in the day care room equal to or greater than 8% of the floor area or is artificial light provided? Yes\_\_\_ No\_\_\_
11. Is one-half of the window area openable, or is the space mechanically ventilated with a minimum of 5 air changes of fresh air per hour? Yes\_\_\_ No\_\_\_
12. Are all fuel-burning space heaters, fireplaces, and floor furnaces, which are listed and approved, provided with a protective screen attached securely to a substantial support in such a way that children will not be burned? N/A\_\_\_ Yes\_\_\_ No\_\_\_

**HEATING SYSTEMS/MECHANICAL**

13. Is the building free of unvented fuel burning or portable electric space heaters? Yes \_\_\_\_\_ No \_\_\_\_\_
14. Have air conditioning, ventilation, heating, cooking, and other service equipment been inspected and approved by the appropriate inspectors? Yes \_\_\_\_\_ No \_\_\_\_\_
15. Is combustion and ventilation air for boiler or heater rooms taken directly from and discharged to the outside of the building (N/A if electric heat is installed)? N/A \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_

**PLUMBING**

16. Do the visible and accessible portions of the plumbing system comply with applicable sections of the Plumbing Code as determined by the appropriate inspector? Yes \_\_\_\_\_ No \_\_\_\_\_
- Date Inspected \_\_\_\_\_

**ELECTRICAL**

17. Do the visible and accessible portions of the electrical system comply with applicable sections of the Electrical Code as determined by the appropriate inspector? Yes \_\_\_\_\_ No \_\_\_\_\_
- Date Inspected \_\_\_\_\_